



Ref. Certif. No.

SE-85062

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR
ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**

CB TEST CERTIFICATE

Product

Moulded case circuit breakers

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang,
Yueqing, Zhejiang Province, 325603 P.R. CHINA

Name and address of the manufacturer

Same as above

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

See page 2

Trademark (if any)

CHNT

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

DZ47-60G, eBC

Additional information (if necessary may also be
reported on page 2)

-

A sample of the product was tested and found
to be in conformity with

IEC 60947-2:2016

As shown in the Test Report Ref. No. which forms part
of this Certificate

160902260SHA-001, 160902260SHA-002, 160902260SHA-003,
160902260SHA-004

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 22 November 2016

Intertek

Signature:

Bo Berglöv

Ratings and principal characteristics

Ue= 240V~(1P), 415V~(2, 3, 4P), 50/60Hz

In= 1, 2, 3, 4, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63A

Ui= 500V~, Cat. A

DZ47-60G: Icu= Ics= 6kA(1-40A), Icu= Ics= 4,5kA(50-63A)

eBC: Icu= Ics= 3kA

Additional information (if necessary)

Date: 22 November 2016

Signature:

