



# 产品认证证书

证书编号: CQC2018010307109393

**申请人名称及地址**

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

**制造商名称及地址**

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

**生产企业名称及地址**

上海诺雅克电气有限公司(V012845)  
上海市松江区思贤路3857号

**产品名称和系列、规格、型号**

万能式断路器  
NA8-1600H; 详情见附件

**产品标准和技术要求**

GB/T14048.2-2008

**认证模式**

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求, 特发此证。

发证日期: 2020年06月01日      有效期至: 2023年08月30日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: \_\_\_\_\_

陆楠



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0290278



# PRODUCT CERTIFICATE

**CERTIFICATE NO.:** CQC2018010307109393

**NAME AND ADDRESS OF THE APPLICANT**

Zhejiang CHINT Electric Co., Ltd.  
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

Zhejiang CHINT Electric Co., Ltd.  
No.1 CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE FACTORY**

NOARK Electrics (Shanghai) Co., Ltd. (V012845)  
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

**PRODUCT NAME, MODEL AND SPECIFICATION**

Air Circuit Breaker  
NA8-1600H; See the appendix

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.2-2008

**TYPE OF CERTIFICATION SCHEMES**

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

**Valid from:** Jun.01,2020

**Valid until:** Aug.30,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

**President:**

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0290278





# 产品认证证书

附录

第 1 页 共 2 页

证书编号: CQC2018010307109393

纸号: 290278

NA8-1600H

额定冲击耐受电压(Uimp):12kV;

额定绝缘电压(Ui):1000V;

额定工作电压(Ue): AC380V/400V/415V, AC690V;

额定电流(In): 400A, 6300A, 800A, 1000A, 1250A, 1600A;

过电流脱扣器类型:电子式;

Ics=55kA (AC380V/400V/415V), 36kA (AC690V);

Icu=65kA (AC380V/400V/415V), 36kA (AC690V);

Icw=42kA/1s (AC380V/400V/415V), 30kA/3s (AC380V/400V/415V),

36kA/1s (AC690V), 30kA/3s (AC690V);

使用类别: B;

极数: 3P, 4P;

适用于隔离;

适用频率: 50/60Hz;

符合附录 N 的电子附件:

欠压脱扣器:

Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;

分励脱扣器:

Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;

闭合线圈:

Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;

辅助触头(本体):

4NO4NC, 6NO6NC;

Ui: 500V;

注: 此附录与证书同时使用时有效。

主任:

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



# 产品认证证书

附录

第 2 页 共 2 页

证书编号: CQC2018010307109393

纸号: 290278

Ith: 6A;

Ue/Ie: AC-15: AC240V/415V/2A;

DC-13: DC110V/220V/0.25A;

注: 此附录与证书同时使用时有效。

主任: \_\_\_\_\_

陆杨



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>