



# 产品认证证书

证书编号: CQC2015010307768641

**申请人名称及地址**

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

**制造商名称及地址**

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

**生产企业名称及地址**

上海诺雅克电气有限公司(V012845)  
上海市松江区思贤路3857号

**产品名称和系列、规格、型号**

万能式断路器  
NA8-2500H; 详情见附件

**产品标准和技术要求**

GB/T14048.2-2008

**认证模式**

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求, 特发此证。

发证日期: 2020年06月01日      有效期至: 2024年12月31日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任: \_\_\_\_\_

陆楠



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0290262



# PRODUCT CERTIFICATE

**CERTIFICATE NO.:** CQC2015010307768641

**NAME AND ADDRESS OF THE APPLICANT**

Zhejiang CHINT Electric Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

Zhejiang CHINT Electric Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE FACTORY**

NOARK Electric (Shanghai) Co., Ltd. (V012845)  
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

**PRODUCT NAME, MODEL AND SPECIFICATION**

Air Circuit Breaker  
NA8-2500H; See the appendix

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.2-2008

**TYPE OF CERTIFICATION SCHEMES**

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

**Valid from:** Jun.01,2020

**Valid until:** Dec.31,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

**President:**

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0290262





# 产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC2015010307768641

纸 号: 290262

NA8-2500H

额定绝缘电压( $U_i$ ): 1000V

额定冲击耐受电压( $U_{imp}$ ): 12kV;

额定工作电压( $U_e$ ): AC380/400/415V, AC690V

额定电流( $I_n$ ): 630A, 800A, 1000A, 1250A, 1600A, 2000A, 2500A

过电流脱扣器类型: 电子式

额定运行短路分断能力( $I_{cs}$ ): AC380V/400/415V:  $I_{cs}=85kA$ ; AC690V:  $I_{cs}=65kA$

额定极限短路分断能力( $I_{cu}$ ): AC380V/400/415V:  $I_{cu}=85kA$ ; AC690V:  $I_{cu}=65kA$

额定短路耐受电流( $I_{cw}$ ): AC380V/400/415V:  $I_{cw}=85kA/1s$ ,  $I_{cw}=50kA/3s$ ;

AC690V:  $I_{cw}=65kA/1s$ ,  $I_{cw}=50kA/3s$ ;

使用类别: B

极数: 3P, 4P

配用的辅助触头(4NO4NC, 6NO6NC):

$I_{th}$ : 6A

AC-15:  $U_e/I_e$ : AC230V/1.3A, AC415V/0.75A

DC-13:  $U_e/I_e$ : DC110V/0.55A, DC220V/0.27A

符合附录 N 的电子附件:

欠压脱扣器:

$U_s$ : AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;

分励脱扣器:

$U_s$ : AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;

闭合线圈:

$U_s$ : AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V 50/60Hz;

注: 此附录与证书同时使用时有效。

主任: \_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>