



# 产品认证证书

证书编号: CQC2019010307211593

**申请人名称及地址**

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

**制造商名称及地址**

浙江正泰电器股份有限公司  
浙江省乐清市北白象镇正泰工业园区正泰路1号

**生产企业名称及地址**

上海诺雅克电气有限公司(V012845)  
上海市松江区思贤路3857号

**产品名称和系列、规格、型号**

万能断路器

NA8-7500, NA8-7500H; 详见附件

**产品标准和技术要求**

GB/T14048.2-2008

**认证模式**

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求, 特发此证。

发证日期: 2020年06月01日      有效期至: 2020年06月03日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: \_\_\_\_\_

陆楠



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0282702



# PRODUCT CERTIFICATE

**CERTIFICATE NO.: CQC2019010307211593**

**NAME AND ADDRESS OF THE APPLICANT**

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China

**NAME AND ADDRESS OF THE FACTORY**

NOARK Electrics (Shanghai) Co., Ltd. (V012845)  
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

**PRODUCT NAME, MODEL AND SPECIFICATION**

Air Circuit Breaker  
NA8-7500, NA8-7500H; See the Appendix

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.2-2008

**TYPE OF CERTIFICATION SCHEMES**

Type testing of product + initial factory inspection + follow up factory inspection  
This is to certify that the above mentioned product(s) complies with the requirements of certification  
rules of CQC11-462141-2019 .

Valid from: Jun.01,2020

Valid until: Jun.03,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing  
certification body until the expiry date.

**President:**

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0282702





# 产品认证证书

附 录

第 1 页 共 2 页

证书编号: CQC2019010307211593

纸 号: 282702

NA8-7500, NA8-7500H

Ui: 1000V;

Uimp: 12kV;

Ue: AC220/380/400/415/440V, AC525/660/690V;

In: 4000A, 5000A, 6300A, 7500A;

过电流脱扣器类型: 电子式;

Ics, Icu 和 Icw 见下表:

Ue	In	型号	Ics (kA)	Icu (kA)	Icw (kA) /1s	Icw (kA) /3s
AC220/380/400V/415V/440V	4000A, 5000A, 6300A, 7500A	NA8-7500	135	135	135	100
AC525/660/690V	4000A, 5000A, 6300A, 7500A	NA8-7500	100	100	100	100
AC220/380/400V/415V/440V	4000A, 5000A, 6300A	NA8-7500H	135	150	135	100
AC220/380/400V/415V/440V	7500A	NA8-7500H	150	150	135	100
AC525/660/690V	4000A, 5000A, 6300A, 7500A	NA8-7500H	100	100	100	100

使用类别: B 类; 适用频率: 50/60Hz;

适用于隔离; 极数: 3P, 4P;

配用的辅助触头: 4NO4NC, 6NO6NC Ith: 6A

AC-15: Ue/Ie: AC230V/1.3A, AC415V/0.75A;

DC-13: Ue/Ie: DC220V/0.27A, DC110V/0.55A

符合附录 N 带电子电路的附件:

闭合线圈: Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V;

注: 此附录与证书同时使用时有效。

主任:

陆梅

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>







# 产品认证证书

附 录

第 2 页 共 2 页

证书编号: CQC2019010307211593

纸 号: 282702

欠压脱扣器: Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V;

分励脱扣器: Us: AC48V/DC48~60V, AC/DC100~130V, AC/DC200~250V, AC380~440V;

过电流脱扣器: Us: AC220-230V, AC380-415V, DC110V, DC220V

型号解释:

N A 8 - 7500 H

N: 企业特征代号

A: 企业万能式断路器代号

8: 企业设计序号

7500: 壳架电流代号

H: 短路分断能力等级代号, 高分断为 H, 普通无

注: 此附录与证书同时使用时有效。

主任: \_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>